

## AFTER ACTION REVIEW BUILDING (AAR) – Large

**General:** The AAR-Large provides space for personnel to review training exercises. Space is also provided for the installation of required electronics and communications equipment to prepare the review presentation and control rooms to monitor the presentation. All AAR information is collected via fiber optic cabling from the Range Operations Center – Large (ROC-Large), which is described elsewhere in this manual. A theater room is provided with a folding partition to provide the option for two smaller theaters with occupancy of 40 persons each or 80 persons total. Monitors, computers, printers, and associated equipment to aid in AAR editing and development are located in the development room. Windows can be placed above the editing equipment. Where topography permits, a downrange view can be seen. Office space is also provided. An optional outside covered area for boot and gear cleaning can be included.

**Design Drawings:** See ROCA Details in the Appendix of this document.

### Typical Configuration:

Size:	240.8 square meters (2592 square feet)
Occupancy:	85
Foundation:	Concrete slab on-grade with turned-down edges
Shell:	Reinforced split-faced CMU
Roof:	Insulated Standing Seam Metal Roof (SSMR) system
Doors:	Insulated hollow metal
Windows:	Aluminum frame with polycarbonate glazing
Interior Finishes:	Painted CMU, acoustical tile ceiling, sheetrock/metal studs partition walls
HVAC:	Central heat and air - site adapted
Standard Lighting:	Fluorescent
Special Lighting:	Red lenses or red lamps (see Night Operations Lighting), dimming-capable lighting in the theater
Lightning Protection:	Air terminals
Power:	120/240Vac, Single Phase, 3-wire Secondary
Telephone:	Standard Voice Cable (optional)
Data Communication:	Fiber Optic Cable from ROC-Large

**Electrical/Communications:** This section discusses electrical/communication considerations unique to this specific structure type. Downrange power, communication, load, transformers, trenching requirements, etc., are discussed elsewhere in this manual.

**General:** Electrical service to the AAR-Large will be 120/240Volt, single phase, 3-wire secondary; 277/480Volt, three phase, 4-wire; and 120/208Volt, three phase, 4-wire secondary. The voltage supplied must be maintained within 5 percent at a frequency of 60 Hz, +/-0.5. Surge suppression devices will be provided at the service entrance for protection of the AAR-Large distribution system. Rigid steel conduit shall extend a minimum of 1524mm (5 feet) beyond the outside of the building foundation for power circuits entering or leaving the building. The AAR-Large

power distribution panel will have separate circuits for lighting, convenience outlets, communications, and Heating, Ventilation, and Air Conditioning (HVAC) equipment.

Additionally, a quad outlet fed by two dedicated 20-amp circuits should be provided in the base of each Data Termination Rack (DTR) and/or communications rack. Each workstation should be fed by a 120V, 20-amp duplex receptacle on a dedicated 20-amp circuit. In the classroom, 120V, 20-amp duplex receptacles should be provided for each overhead projector and video camera.

Communication: A direct-buried fiber optic cable will connect the AAR-Large and the ROC-Large via the DTR. The cable will enter the buildings via RGS conduit filled with innerduct to facilitate future expansion [Military Construction (MILCON) funded]. The DTR is an enclosed equipment rack where all fiber optic cables are terminated in a cross-connect panel with industry standard type SC connectors (also MCD). A minimum 24-strand fiber optic connection is required between the AAR-Large and the ROC-Large for transporting video and data information. All fiber connections made in the ROC-Large will utilize the SC-form connectors.

A ladder type wireway system is required to extend from the DTR to above the ceiling (MILCON-supplied). A 24 inch ladder type cable tray shall interconnect the workstations and the fiber racks in the AAR Development Room. The AAR Control Center shall be connected to the wireway system via 6-inch cable tray. All data communication conduits shall connect to this wireway to allow for interconnecting of instrumentation components. Camera and video projectors in the AAR Classroom shall be connected to the wireway system via conduits. Provide pull wires in all conduits where cables are to be installed by others.

Other Appropriations-Army (OPA) funded communications equipment will share DTR rack space to convert the fiber optic cables to industry standard. Ethernet copper network cable may be used to make connections with the network, video editing computers, and other instrumentation components. Coordination with OPA contractors should be conducted for location of communication conduits and boxes for networking and video presentation.

Lighting: Fluorescent lighting will be used. Red lamps or lenses for night operation will be provided with protected switching to prevent accidental illumination of white lights during night operations. Due to night firing requirements, all lighting within the AAR if located along the baseline will need to be both white and red to ensure proper range operations. Red light is required during training so as not to ruin the night vision of the soldiers. Where necessary, low-level in-ground lights (similar to airfield markers) may be used for vehicle parking areas and walkways. There is not an Army standard for the lighting system. The designer will need to ensure that the customer's lighting requirements are met.

Night Operations Lighting: To prevent interference with specialized equipment used during night operations, red lenses or red lamps must be provided in addition to standard lighting if the following conditions exist.

- Night training will be performed
- ROCA buildings are near the firing positions
- ROCA building has windows that cannot be covered.

Separate switching for the standard and red lighting shall also be provided, located near points of egress.

Grounding: Grounding is required for safety and for lightning protection. The AAR-L ground system will consist of a buried, No. 4/0 AWG, stranded, copper conductor and ground rods all interconnected to yield an earth resistance of 25 ohms or less. Cable connections and connections to the ground rods and structural steel will be exothermically welded. The DTR and communication rack ground points will be connected to a Single Ground Point (SGP) with at least a No.6 AWG, insulated, stranded, copper cable. The SGP will be connected to the ground system with at least a No. 4/0 AWG, bare, copper cable.

Telephone Communication: Telephone communications are not a requirement. If they are desired, these communications must be coordinated with the local installation's Directorate of Information Management (DOIM).